

Weinzierl Engineering GmbH
Achatz 3
DE-84508 Burgkirchen / Alz
Tel. +49(0)8677 / 916 36 0
Fax +49(0)8677 / 916 36 19
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **IO Extension Shutter 592**
Version: REG
Manufacturer: Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

Low voltage directive 2014 / 35 / EU
EMC directive 2014 / 30 / EU
RoHS directive 2011 / 65 / EU (RoHS2)
EN 60950-1: 2005 + A1: 2009 + A2: 2013 (Electrical safety)
EN 50491-5-1: 2010 (HBES, EMC General)
EN 50491-5-2: 2010 (HBES, EMC Residential)
EN 50491-5-3: 2010 (HBES, EMC Industrial area)
EN 61000-6-2: 2005 (Immunity, Industrial area)
EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential)
EN 50581: 2012 (RoHS2)

Intended use:

The IO Extension Shutter 592 has been specially developed for the control of blinds and shutters. The double relay is connected to only one output of a KNX Multi IO. The direction control of the relay outputs is performed automatically by the KNX Multi IO by a defined voltage interruption of the holding current.

Burgkirchen / Alz, March 13th 2018



Dr. Th. Weinzierl, CEO