

Weinzierl Engineering GmbH
Achatz 3-4
84508 Burgkirchen / Alz
GERMANY
Tel. +49(0)8677 / 916 36 0
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **Multi IO Extension Shutter 592**
Version: REG
Manufacturer: Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

Low voltage directive 2014 / 35 / EU
EMC directive 2014 / 30 / EU
RoHS directive 2011 / 65 / EU (RoHS2)
EN 62368-1: 2020 + A11: 2020 (Electrical safety)
EN 50491-5-1: 2010 (HBES, EMC General)
EN 50491-5-2: 2010 (HBES, EMC Residential)
EN 50491-5-3: 2010 (HBES, EMC Industrial area)
EN 61000-6-2: 2019 (Immunity, Industrial area)
EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential)
EN 63000: 2018 (RoHS2)

Intended use:

The IO Extension Shutter 592 has been specially developed for the control of blinds and shutters. The double relay is connected to only one output of a KNX Multi IO. The direction control of the relay outputs is performed automatically by the KNX Multi IO by a defined voltage interruption of the holding current.

Burgkirchen / Alz, April 11th 2022



Dr. Th. Weinzierl, CEO