

Weinzierl Engineering GmbH
Bahnhofstr. 6
DE-84558 Tyrlaching
Tel. +49(0)8623 / 987 98 03
Fax +49(0)8623 / 987 98 09
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **KNX ENO 620/622**
Version: Wall mounted box
Manufacturer: Weinzierl Engineering GmbH, 84558 Tyrlaching

conforms to the following standards:

- Low voltage directive 73/23/EWG, Edition 07/96
- EMC-Directive 89/336/EWG, Edition 02/96
- R&TTE Directive 1999/5/EC
- Device fulfills EN 50090-2-2 (ESHG) Edition 06/97
- Device fulfills EN 61000-6-2 (Susceptibility) Edition 10/2001
- Device fulfills EN 61000-6-3 (Emissions) Edition 10/2001
- Device fulfills EN 300 220-1: V2.1.1 and EN 300 220-2: V2.1.2 (SRD)

Intended use:

KNX ENO 620/622 acts as a gateway between EnOcean radio sensors and the KNX bus. It has 32 channels, each of which can be configured with one of the following functions: Switch module touch sensor, Temperature sensor, Window contact, Window handle, Binary input, Light sensor and Motion detector. In addition, the device contains six control channels e.g. for room temperature or light.

Tyrlaching, August 18th 2009



Dr. Th. Weinzierl, CEO