

Weinzierl Engineering GmbH
Achatz 3-4
84508 Burgkirchen / Alz
GERMANY
Tel. +49(0)8677 / 916 36 0
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **KNX IP BAOS 774**
Version: REG
Manufacturer: Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany


conforms to the following standards:

EMC directive 2014 / 30 / EU
RoHS directive 2011 / 65 / EU (RoHS2)
EN 63044-3: 2018 (HBES, Electrical safety)
EN 63044-5-1: 2019 (HBES, EMC General)
EN 63044-5-2: 2019 (HBES, EMC Residential)
EN 63044-5-3: 2019 (HBES, EMC Industrial area)
EN 61000-6-2: 2019 (Immunity, Industrial area)
EN 61000-6-3: 2021 (Emission, Residential)
EN 63000: 2018 (RoHS2)

Intended use:

This device is for establishing a bidirectional connection between a PC and the KNX installation bus. The connection over IP conforms to KNX specification (KNXnet/IP). The KNX IP BAOS 774 is used as interface to connect to KNX both on telegram level (KNXnet/IP Tunnelling) and on data-point level (KNX Application Layer). BAOS stands for "Bus Access and Object Server".

Burgkirchen / Alz, February 13th 2024



Dr. Th. Weinzierl, CEO