

Weinzierl Engineering GmbH
Achatz 3-4
84508 Burgkirchen / Alz
GERMANY
Tel. +49(0)8677 / 916 36 0
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **KNX IO 510.1 *secure* (20)**
Version: REG
Manufacturer: Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

Low voltage directive 2014 / 35 / EU
EMC directive 2014 / 30 / EU
RoHS directive 2011 / 65 / EU (RoHS2)
EN 63044-3: 2018 (HBES, Electrical safety)
EN 50491-5-1: 2010 (HBES, EMC General)
EN 50491-5-2: 2010 (HBES, EMC Residential)
EN 50491-5-3: 2010 (HBES, EMC Industrial area)
EN 61000-6-2: 2019 (Immunity, Industrial area)
EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential)
EN 63000: 2018 (RoHS2)

Intended use:

The KNX IO 510.1 *secure* (20) is an actuator with 2 outputs. These outputs can be controlled via the KNX BUS.

Burgkirchen / Alz, March 31st 2022



Dr. Th. Weinzierl, CEO